



1. Low –Emitting is 1 point Weck Voc 46 G/L
2. No formaldehyde is 1 point
3. Certificate of Compliance – VOC Emissions 1350 show no formaldehyde

**IEQc4.2: LOW-EMITTING MATERIALS—PAINTS AND COATINGS REQUIREMENTS**

**Architectural paints, coatings and primers** applied to interior walls and ceilings: Do not exceed the VOC content limits established in Green Seal Standard GS-11, Paints, First Edition, May 20, 1993.

Flats	50 g/L
Non-flats	150 g/L

**Anti-corrosive and anti-rust paints** applied to interior ferrous metal substrates: Do not exceed the VOC content limit of 250 g/L established in Green Seal Standard GC-03, Anti-Corrosive Paints, Second Edition, January 7, 1997.

**Clear wood finishes, floor coatings, stains, sealers, and shellacs** applied to interior elements: Do not exceed the VOC content limits established in South Coast Air Quality Management District (SCAQMD) Rule 1113, Architectural Coatings, rules in effect on January 1, 2004.

Clear wood finishes	Varnish	350 g/L
	Lacquer	550 g/L
Floor Coatings		100 g/L
Sealers	Waterproofing Sealers	250 g/L
	Sanding Sealers	275 g/L
	All other sealers	200 g/L
Shellac	Clear	730 g/L
	Pigmented	550 g/L
Stains		250 g/L

**IE Q Credit 4.2: Low-Emitting Materials—Paints and Coatings**  
**1 Point**

**Intent**

To reduce the quantity of indoor air contaminants that are odorous, irritating and/or harmful to the comfort and well-being of installers and occupants.

**Requirements**

Paints and coatings used on the interior of the building (i.e., inside of the weatherproofing system and applied onsite) must comply with the following criteria as applicable to the project scope:

Architectural paints and coatings applied to interior walls and ceilings must not exceed the volatile organic compound (VOC) content limits established in Green Seal Standard GS-11, Paints, 1st Edition, May 20, 1993.

Anti-corrosive and anti-rust paints applied to interior ferrous metal substrates must not exceed the VOC content limit of 250 g/L established in Green Seal Standard GC-03, Anti-Corrosive Paints, 2nd Edition, January 7, 1997.

Clear wood finishes, floor coatings, stains, primers, and shellacs applied to interior elements must not exceed the VOC content limits established in South Coast Air Quality Management District (SCAQMD) Rule 1113, Architectural Coatings, rules in effect on January 1, 2004.

**Potential Technologies & Strategies**

Specify low-VOC paints and coatings in construction documents. Ensure that VOC limits are clearly stated in each section of the specifications where paints and coatings are addressed. Track the VOC content of all interior paints and coatings during construction.

---

## Certificate of Compliance – VOC Emissions

### DC315 Paints and Coatings

### International Fireproof Technology Inc.

International Fireproof Technology Inc. selected a sample representative of its DC315 Paints and Coatings, water based fire proof paint, and submitted it for testing on February 2, 2010. Berkeley Analytical measured and evaluated the emissions of volatile organic compounds (VOCs) from this sample according to California Department of Health Services (CDHS) *Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers* (CA/DHS/EHLB/R-174, 2004; also known as, chamber testing portion of CA Section 01350) and ASTM Standard Guide D 5116-06. Chemical sampling and analysis were performed following U.S. EPA Compendium Methods TO-1 and TO-17 and ASTM Standard Method D 5197-03.

Calculations were performed with the following standard classroom and office exposure parameters to project the concentrations of VOCs of concern resulting from the use of this product. The results of the test and the calculated concentrations for the classroom and office are presented in Berkeley Analytical laboratory report, 469002-01A-Feb2410.

#### **Summary of Emission Test Results**

**VOC Emission Test Results** – The pass/fail results of the test with respect to the procedures and acceptance criteria given in the CA DHS *Standard Practice* and the modeling scenario(s) from the *Standard Practice* detailed in Table 3 of this report are summarized in Table 1. These results are based on predicted indoor air concentrations of individual VOCs in the modeled scenario(s). The concentration limits are one half the non-cancer Chronic Reference Exposure Levels (CRELs) established by California OEHHA for a list of toxic chemicals with the exception of formaldehyde, for which the guideline concentration is one-half the indoor REL of 33 µg/m<sup>3</sup>, i.e., 16.5 µg/m<sup>3</sup> as described in the CA DHS *Standard Practice* and its Addendum 2004-01. Note that OEHHA published a new hazard assessment for acetaldehyde in December 2008, setting the CREL for this compound at 140 µg/m<sup>3</sup>. These test results are specific to the test item.

**Table 1.** Pass/fail results of test based on test method and identified modeling parameters.

Only detected individual VOCs with CRELs are listed.

No formaldehyde or other CREL VOCs were detected **None: PASS:** Standard Classroom and/or Office Space

**Based on these results, the tested product sample meets the VOC emission requirements for use in classroom and office environments as defined in the CA DHS *Standard Practice*. Thus, the testing requirements are met to qualify the product as a low-emitting material in the Collaborative for High Performance Schools rating system (CHPS Designed & CHPS Verified).**

Certificate No.: 100224-01

Dated: February 24, 2010